

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BBAY1*,
MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BFC2Y1*,
MTS: UATYA(30/40/50/60/70/80/90/100/110/120/140/150/160/180/190)BFC3Y1*,
MTO: 30***..., 40***..., 50***..., 60***..., 70***..., 80***..., 90***..., 100***..., 110***..., 120***..., 140***..., 150***..., 160***..., 180***..., 190***...,
*= , 1,2,3,...,9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008*** as amended,
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*
S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

following the provisions of: BS EN 60204-1: 2018, BS EN 61000-6-3: 2021, BS EN 61000-6-2: 2019, BS EN 378-2: 2016, IEC 60335-2-40: 2018,

* as set out in <A> and judged positively by according to the **Certificate <C>**.
** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>) according to the **Certificate <G>**. Risk category <H>. Also refer to next page.
*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

<A>	—
	—
<C>	—
<D>	—
<E>	Bureau Veritas Italia S.p.A. (NB1370)
<F>	H
<G>	—
<H>	III

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: <L> (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	46 bar
<L>	TSmin	–20 °C
<M>	TSmax	150 °C
<N>		R32
<P>		44 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

<Q>	Bureau Veritas Italia S.p.A. Via Miramare 15, 20126 Milano (MI), Italy
-----	--